

INSTRUCTIONS: Flexrail2 Jumper Cable

Models: HM-JSC12 HM-JSC24 HM-JSC36

Safety Instructions:

For installation by a qualified electrician.

System is intended for installation in accordance with National Electric Code, local and Federal code specifications.

To reduce the risk of fire, electrical shock and injuries to persons:

1. Turn off power at main switch before installing or modifying the system.
2. Do not load rail to more than 20 amps per circuit.

Installing Jumper:

The jumper cable is comprised of two top feeding power adapters.

1. Loosen the cap ring counter clockwise and remove it.
2. Grasp the thumb holds of the bottom plug, and pull it straight out.
3. Place the rail into the recess of the adapter and re-install the bottom plug.
4. Re-install the cap ring.

